

**EXPANDA FENCE EDGE PROTECTION SYSTEM
INSPECTION & HANDOVER CERTIFICATE**



PROJECT	
PRINCIPAL	
GRIDS	
LEVEL	

ITEM	CONTROL	CONFIRMED
ANCHORS		
TYPE	HILTI HUS-H M12.5 X 70	
QTY PER STIRRUP	3	
CONDITION	Screwhead seated flat against stirrup plate	
STIRRUPS		
CONDITION	Rigid & Plumb	
DISTANCE APART	3.5m Max	
CLAMP	Tight, securely engaged against panel	
PANELS		
CONDITION	Secure and level	
OVERLAP	200mm Min.	
OVERRUN	50MM Min.	
KICKBOARDS		
CONDITION	Engaged, clamped, right way up	
OVERLAP	200mm Min.	
OVERRUN	50MM Min.	
POCKET FLAPS		
CONDITION	Captive in kickboards	
POSITION	Covering the pockets	
MESH PANELS		
CONDITION	Hooked over top handrail	
POSITION	Gaps no greater than 50mm	
EXCLUSION ZONE CHAIN		
CONDITION	Secured to stirrups, no breaches	
INSTALLATION SUPERVISOR		DATE
NAME		
SIGNATURE		